

## **Analysis of streams in local systems with distributed generation by methods of graph theory**

KOZYRSKIY V., KAPLUN V.

National University of Life and Environmental Sciences of Ukraine, Ukraine

**Abstract:** *Analysis of streams in local systems with distributed generation by methods of graph theory.* The graph theory is a simple and powerful construction tool of models and optimization of analyzed tasks. Now there is a set of problems where it is required to construct difficult complex systems. There are solved in view of the certain ordering of their elements. The choice of optimum routes and streams in electro-generating networks, constructions of independent source of electricity in changing topology networks with distributed generation are concerned.

*Key words:* electro-generating networks, graph theory, linear programming.

Distributed generation (DG) is an emerging concept in the electricity sector, which represents good alternatives for electricity supply instead of the traditional centralized power generation concept. The electrical grid is one of the largest infrastructures ever built. This infrastructure has been built regarding a generation model where large centrals should provide the electricity to supply all the customers. In this grid topology, the power produced by these centrals is transmitted in HV to consumption points, changing there to MV for its distribution and finally is transformed to LV for its consumption. Due to environmental concerns and the variable price of fossil fuels, renewable energy sources are getting more importance for power generation.

Even if large wind farms or hydroelectric centrals are connected to the transmission grid, a large amount of renewable energy is connected to the local network. These generation units can be defined as distributed generation. The increasing penetration of DG is already changing the network topology [1, 2].

The graph theory is a simple and powerful construction tool of models and optimization of analyzed tasks [3, 4]. This theory has simple elements and ideas in the basis: the points connected by lines that allows to build of them rich variety of forms and as a result to become useful means at research of various systems. Now there is a set of problems where it is required to construct difficult complex systems. There are solved in view of the certain ordering of their elements. The choice of optimum routes and streams in electro-generating networks, constructions of independent source of electricity are concerned.

At studying streams it is enough to be limited focused coherent graphs. Such graphs will refer to as networks [3, 5].

In network  $N$  is a function  $\varphi$ . It has determined on  $A$ . Integer  $\varphi(a)$  refers as a stream on an arch  $a$ . If  $a \equiv (\upsilon, \omega)$ , so the stream is directed from  $\upsilon$  to  $\omega$  at  $\varphi(a) \geq 0$  and from  $\omega$  to  $\upsilon$  at  $\varphi(a) \leq 0$ .

The direction of a stream is defined by familiar  $\varphi(a)$ .

Tops of network  $N$  are usually classified on their influence on a stream  $\varphi$  (create, absorb or keep a stream). To formalize classification, we shall designate through  $v \rightarrow V$  set of arches for which  $v$  is initial top, and through  $V \rightarrow v$  – set of arches for which  $v$  is final top. Then integer  $Q(v, \varphi)$  is determined by a correlation:

$$Q(v, \varphi) = \sum_{v \rightarrow V} \varphi(a) - \sum_{V \rightarrow v} \varphi(a) \quad (1)$$

It is called to *as a clean stream* from  $v$  be relative  $\varphi$ . If  $\varphi(a) \geq 0$  is in each arch, so the first sum is simply general stream following from top  $v$ . The second is the general stream flowing into top  $v$ . If in some arches streams are negative, the allocated sums have no named interpretation. Their difference are still represent a clean stream from top  $v$ .

The tops of network  $N$  are grouped in sets  $V^+$ ,  $V^-$  and  $V^0$  as follows:

$$\begin{aligned} V^+ &= \{v \in V / Q(v) > 0\} \\ V^- &= \{v \in V / Q(v) < 0\} \\ V^0 &= \{v \in V / Q(v) = 0\} \end{aligned} \quad (2)$$

Elements of sets  $V^+$ ,  $V^-$  and  $V^0$  are called as sources, drains and intermediate tops. These tops accordingly are create, consume and keep a stream.

The network keeps in whole any stream  $\varphi$  such as  $\sum_{v \in V} Q(v) = 0$

It is easy to see in the following expression:

$$\sum_{v \in V} Q(v) = \sum_{v \in V} \sum_{a \in (v \rightarrow V)} \varphi(a) - \sum_{v \in V} \sum_{a \in (V \rightarrow v)} \varphi(a) \quad (3)$$

Each arch of a network enters once into each double sum.

The circuit of autonomous system of power supply is resulted on Figure 1:

$v_1$  – the centralized source of electric supply;

$v_2$  – the autonomous power station with a drive motor of internal combustion;

$v_3$  – the accumulator of energy and the static converter of the electric power;

$v_4$  – the electric consumer.




FIGURE 1. The graph of a network

Energy source we shall designate through 1, and a drain through 2. The characteristics of tops and arches the graph are resulted on the Table 1.

If in a network there is only one source  $v_i$  and only one drain  $v_j$ , the stream is

TABLE 1. The table of characteristics of graph tops

	$v_1$	$v_2$	$v_3$	$v_4$
1	1	-1	0	0
2	0	1	-1	0
3	0	0	1	-1
4	1	0	0	-1
5	0	1	0	-1

considered from  $v_i$  in  $v_j$ . The size  $Q(v_i)$  or  $Q(v_j)$  is called *as size of a stream*. For convenience the same terminology is distributed in a case of streams of zero size, for which  $Q(v) = 0$  in all tops.

Any stream in the network can be transformed to a stream which has only one source and one drain and increased amount of tops in network. For example, we shall add new top  $\omega_1$  and arches  $b_i \equiv (\omega_1, v_i)$ , leaders from  $\omega_1$ , to each source of a network. To these arches we shall attribute a stream

$$\varphi(b_i) = Q(v_i) \tag{4}$$

Similarly, we shall add the second top  $\omega_2$  and arches  $c_j \equiv (v_j, \omega_2)$ , which conduct from each drain to top  $\omega_2$  and have a stream

$$\varphi(c_j) = -Q(v_j) \tag{5}$$

In result we shall receive a network with one source and one drain. We shall consider attitudes between streams. Let  $\varphi_1$  and  $\varphi_2$  are streams in same network  $N = (V, A)$ , and let  $p$  is an integer. Then for each arch  $a \in A$ . The streams  $\varphi_1 + \varphi_2$ ,  $\varphi_1 - \varphi_2$  and  $p\varphi$  are defined with the help of the following parities:

$$\begin{aligned} (\varphi_1 + \varphi_2)(a) &= \varphi_1(a) + \varphi_2(a) \\ (\varphi_1 - \varphi_2)(a) &= \varphi_1(a) - \varphi_2(a) \\ (p\varphi_1)(a) &= p\varphi_1(a) \end{aligned} \tag{6}$$

It is easy to see, that

$$\begin{aligned} Q(v, \varphi_1 \pm \varphi_2) &= Q(v, \varphi_1) \pm Q(v, \varphi_2) \\ Q(v, p\varphi_1) &= pQ(v, \varphi_1) \end{aligned}$$

From here follows, that if  $\varphi_1$  and  $\varphi_2$  are streams from  $v$  in  $\omega$ , having sizes  $k_1$  and  $k_2$  accordingly  $\varphi_1 + \varphi_2$  also is a

stream from  $v$  in  $\omega$  and has size  $k_1 + k_2$ . Similarly,  $\varphi_1 - \varphi_2$  there is a stream having size  $k_1 + k_2$ . and directed from  $v$  to  $\omega$ , if  $|k_1 - k_2|$  or from  $\omega$  to  $v$ , if  $k_1 \leq k_2$ . (The stream of bullets size can be counted as direct from both  $v$  to  $\omega$ , and from  $\omega$  to  $v$ .) And at last, the stream  $p\varphi$  has size  $|pk_1|$  and is directed from  $v$  to  $\omega$ , if  $p \geq 0$ , and from  $\omega$  to  $v$ , if  $p \leq 0$ .

Let's result substantive provisions of linear programming in networks.

Let tops  $v_0$  and  $v_n$  are focused the graph designate a source and a drain of some substance proceeding on arches. Besides we shall assume, that from top  $v_i$  in top  $v_j$  throughput or the top restriction on size of stream  $C_{ij}$  is put to an arch in conformity. At last, let  $C_{ij}$  is designated cost of unit of a stream on an arch. Now the task about a stream can be presented as a task of linear programming.

It is required to minimize  $\sum_{i,j} C_{ij}\chi_{ij}$  for the general stream *with* from  $v_0$  in  $v_n$  under conditions:

$$\sum_j (\chi_{0j} - \chi_{j0}) = c \tag{7}$$

$$\sum_j (\chi_{ij} - \chi_{ji}) = 0 \text{ for } i = 1, \dots, n - 1$$

$$\sum_j (\chi_{nj} - \chi_{jn}) = -c \tag{8}$$

$$0 \leq \chi_{ij} \leq c_{ij} \text{ for each arch.}$$

Streams in networks sometimes are appeared convenient means of the decision of a task of linear programming. Such type which is known under the name of a transport task.

## REFERENCES

1. AULT G.W. 2000: A Planning and Analysis Framework for Evaluating Distributed Generation and Utility Strategies, PhD Thesis, September 2000, Centre for Electrical Power Engineering, Department of Electronic and Electrical Engineering, University of Strathclyde.
2. ACKERMAN T., ANDERSSON G., SÖDER L. 2001: Distributed generation: a definition, *Electric Power Systems Research-Elsevier*, vol. 57, pp. 195–204(10), 20 April 2001.
3. HARARY F. 1995: *Graph Theory*. Narosa Publishing House, New Delhi.
4. NIKULSHIN V., WU C. Method of thermodynamic analyses and optimization of energy intensive systems of exergy flow graphs//*Proceedings of SASTED International Conference on Power and Energy Systems*. Las Vegas, Nevada, USA, pp. 489–491.
5. WU C., NIKULSHIN V. 2000: Method of thermo-economical optimization of energy intensive systems with linear structure

of graphs. *International of Energy Research*, 24, pp. 615–623.

**Streszczenie:** *Analiza przepływów w systemach lokalnych z rozproszoną generacją przy użyciu metod teorii grafów.* Teoria grafów jest prostym i mocnym narzędziem w konstrukcji modeli i optymalizacji analizowanych zadań. Obecnie występuje wiele problemów wymagających konstruowania trudnych i złożonych systemów. Są one rozwiązywane w celu pewnego uszeregowania ich elementów. Dotyczy to wyboru optymalnych ścieżek i przepływów w sieciach wytwarzania energii elektrycznej, konstrukcjach niezależnych źródeł elektryczności i zmianach sieci topologicznych o rozproszonej generacji.

*MS. received April 2011*

**Authors' address:**

Kozyrskiy V., Kaplun V.  
Education and Research Institute of Energetic and Automation National University of Live and Environmental Sciences of Ukraine  
Heroyiv Oborony str. 15  
03041 Kiev  
Ukraine